

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer TE Connectivity
Freebournes Road, Witham
Essex CM8 3AH
United Kingdom

Measuring instrument A static **Active Electrical Energy Meter**

Type : DRR-XX-1P, DRR-XXX-1P, DRR-XXX-3P

Manufacturer's mark or name : TE Connectivity

Reference voltage : 230 V, 3x230V, 3x230/400V

Reference current : 0,1A (DRR-RJX-XX), 1A (DRR-CTX-XX), 5A (DRR-45-XX, DRR-100-XX)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network (DRR-XXX-3P)
- three-phase three-wire network (DRR-XXX-3P)
- single-phase two-wire network (DRR-XX-1P, DRR-XXX-1P, DRR-XXX-3P)

Accuracy class : B

Environment classes : M1 / E2

Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:
- Description T13149 revision 0;
- Documentation folder T13149-1.

Valid until 30 December 2035

Initially issued 30 December 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
30 December 2025

Certification Board